



Product Service

CERTIFICATE

No. Z10 14 02 60643 007

Holder of Certificate: **RTP Corporation**
2832 Center Port Circle
Pompano Beach FL 33064
USA

Factory(ies): 60643

Certification Mark:



Product: **Safety Related Programmable Electronic System**

Model(s): **RTP3000 TAS**

Parameters:

| | |
|------------------------|--------------------|
| Option 1: | |
| Operating Voltage: | 18-36VDC |
| Input Current: | Less than 10A |
| Option 2: | |
| Operating Voltage: | 85-264VAC, 47-63Hz |
| Input Current: | Less than 4A |
| Operating Temperature: | -20°C to +60°C |

Tested according to:

- IEC 61508-1:2010 (SIL 1-3)
- IEC 61508-2:2010 (SIL 1-3)
- IEC 61508-3:2010 (SIL 1-3)
- IEC 61508-4:2010 (SIL 1-3)
- IEC 61511-1:2003 (SIL 1-3)
- IEC 61131-6:2012 (SIL 1-3)
- NFPA 72:2013
- NFPA 85:2011
- EN 54-2:1997

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: RP85295C

Date, 2014-02-07 (Peter Weiss)



Page 1 of 1